

Product Certification Schedule

| | | |
|-------------------|---------|---|
| Schedule No. | (r1) : | 087/001/022 |
| Licensee: | (r4) : | SYRIAN MODERN CABLE COMPANY, ADRA, TEL KURDI, DAMASCUS, SYRIA |
| Factory: | (r5) : | SYRIAN MODERN CABLE COMPANY, ADRA, TEL KURDI, DAMASCUS, SYRIA |
| Specification | (r7) : | BS5467:1997 - Specification for 600/1000V and 1900/3300V armoured electric cables having thermosetting insulation. |
| Type of Cable | (r9) : | Table 8 - Three-core 600/1000V cables with stranded copper conductors |
| HAR Document | (r8) : | Not applicable |
| HAR Specification | (r10) : | Not applicable |
| Range of Approval | (r11) : | 1.5qmm to 400sqmm nominal cross-sectional area of conductors inclusive. 3-Core. Sheath - Type 9 and Insulation - GP8. |
| Origin Thread | (r12) : | Not applicable |
| Origin Mark | (r13) : | SMC |

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to Section 4 of the BASEC Product Marking Handbook

Expiry Date: 18/01/2009



Signed for and on behalf of the British Approvals Service for Cables

Graham R O'Keefe

Date 06/03/2006 (r2)

