

**TYPE TEST CERTIFICATE OF COMPLETE TYPE TEST**

**OBJECT** three-core power cable

**DESIGNATION** 19/33 (36) kV, 3x240 mm<sup>2</sup> Cu, XLPE

**MANUFACTURER** SYRIAN MODERN CABLE  
Tel Kurdi – Adra – Damascus – Syria

**DATE OF TESTS** 23 March up to and including 27 April 2006

**TESTED BY** KEMA HIGH-VOLTAGE LABORATORY,  
Utrechtseweg 310 - 6812 AR Arnhem - the Netherlands

The object, constructed in accordance with the discription, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

**IEC 60502-2**

**This Type Test Certification has been issued by KEMA following exclusively the STL guides. The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 2. The Certificate applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the manufacturer.**

This Certificate comprises 31 sheets in total.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the object tested, are permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.

A handwritten signature in black ink, appearing to be "P.G.A. Bus", written over the printed name.

P.G.A. Bus  
KEMA T&D Testing Services  
Managing Director

Arnhem, 21 June 2006

